PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO.- 111 DATE- 03.05.2026

It is certified that an inspection team headed by RAJAT SHARMA AEN PHED BABAI (Name of Officers with designation) From PHED BABAI (Name of Department/Office) inspected the Paramount Public School, Teh. Khetri, D.-JJN (RAJ) PH-332746. (Name & Address of the School) on 3/5/2026 and found that the Paramount Public School, Thathwadi, Khetri, D-JJN (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above are valid for a period of 05.05.2027

Signature with Seal:

Name: (रजत शर्मा) सहायक अभियन्ता जल स्वा. अधि. विभाग खेतड़ी उपखण्ड झुंझुनूं

Designation:

To

The Paramount Public School,
Vpo.-Thathwadi, Teh.- Khetri,
D.-JJN, (RAJ.) - 332746

(Name & Address of the Institution)

PUBLIC HEALTH ENGINEERING DEPARTMENT
LABORATORY JHUNJHUNU

CHEMICAL EXAMINATION REPORT OF WATER

No. Lab. / Chem. /2026-27/ 118 **Date -** 5-5-2026

To,
The Principal
The Paramount Public School
Thathwari

District – Jhunjhunu
Tehsil - Khetri

Ref- Your letter no.OFF/PPS/2025-26/354 dated 22.04.26

Date of Exam – 05.05.26

A	Name & Location of Source	IS-10500:2012		Water Sample The Paramount Public School
B	Village/ Town			Thathwari
C	Date Of Collection			04-05-26
D	Lab. Sample No.			C-029
Sr. No	Parameters	Desirable limits	Permissible limits	Value
1	pH	6.5—8.5	6.5—8.5	6.87
2	Turbidity[NTU]	1	5	Nil
3	Temperature[C]	------	------	25
4	Colour[Units]	5 Hazen Unit	15 Hazen Unit	None
5	Odour	Unobjectionable	Unobjectionable	Unobj.
6	Residual Chlorine	0.2	1.0	Nil
7	Total Alkalinity[as $CaCO_3$]	200	600	40
8	Total Hardness[as $CaCO_3$]	200	600	16
9	Chloride[as Cl^{-1}]	250	1000	28
10	Nitrate[as NO_3^{-1}]	45	45	03
11	Fluoride [as F^{-1}]	1.0	1.5	0.12
12	Sulphate [as SO_4^{-2}]	200	400	06
13	TDS	500	2000	115

Note:1- All Results Except pH in mg/L.
2- This report is not valid for legal cases/legal purposes.

(S K Sharma)
Junior Chemist
PHED Laboratory Jhunjhunu